



Notes

- GENERAL NOTES:
1. Do not scale drawing. Use figured dimensions only.
 2. Report any discrepancies immediately to the Design Team.
 3. This drawing to be read in conjunction with all other relevant Architectural, Mechanical/Electrical and Engineering Drawings.
 4. All works carried out must comply with the relevant parts of the current Building Regulations and Technical Guidance Documents, ensuring the works are carried out using 'proper materials which are fit for use for which they are intended and for the conditions in which they are used'.
 5. All materials used shall be marked in accordance with the EU Construction Product Regulations (CPR) (No. 305/2011). Refer to Annex IV of the Regulations for the list of applicable products.
 6. Details of the treatment of all existing water services to the site, shall be agreed with Irish Water.
 7. Number of fire hydrants to be agreed with the Fire Officer.
 8. All valves, 100mm or greater, shall be anti-clockwise closing.
 9. All road and footway water fitting covers, shall be marked to indicate what is underneath.
 10. Marker plates shall be installed for all existing and new watermain fittings, on or adjoining the site, to the satisfaction of Irish Water.
 11. All watermains and fittings to be laid in accordance with Irish Water Infrastructure Standard Details Document Number IW-CDS-5020-01 and Irish Water Code of Practice for Water Infrastructure Document IW-CDS-5020-03.



PROPOSED WATERMAIN LAYOUT
SCALE 1:500

LEGEND:

	SITE OUTLINED IN RED
	PROPOSED 100mm Ø MDPE WATERMAIN
	EXISTING IRISH WATER WATERMAIN
	PROPOSED SLUICE VALVE
	FIRE HYDRANT
	PROPOSED BULK WATER METER
	PROPOSED CUSTOMER DISTRIBUTION SERVICE MANIFOLD
	EXISTING WATER FEED TO BE BLANKED OFF

P	June 22	ME	Issued for Part 8 Planning	PF
Rev	Date	Drawn	Description	CHK'd

rka
CONSULTING ENGINEERS
CIVIL | STRUCTURAL | PROJECT MANAGEMENT

2 Clogheen Business Park,
Blarney Road, Cork,
Ireland.
T: +353 (0)21 4399799
F: +353 (0)21 4399797
E: admin@rka.ie
W: www.rka.ie

Client:
Cetti Ltd.

Project:
Proposed Development
A1 Kinsale Road, Cork City.

Drawing Title:
Proposed Watermain Layout

Designed: PF	Drawn: ME	Date: June 2022
Eng Chk: PF	Dwg. Chk: PF	Scale: 1:500 @ A3
Project No: 0567002	Drawing No: 1003	Status: Planning
Rev: P		