



FOUL PUMP STATION PUMP SPEC:

1. DUTY & STANDBY PUMP ARRANGEMENT
2. EACH PUMP TO BE FITTED WITH MACERATOR
3. PUMP SET TO DISCHARGE AT 2.0L/S (TBC BY PUMP SUPPLIER)
4. LENGTH OF THE RISING MAIN = CIRCA 30m (TBC ON SITE)
5. HEAD Excl LOSSES = 5.5m
6. PUMP SUPPLIER TO CONFIRM THE SIZE OF THE RISING MAIN

LEGEND:

PROPOSED FOUL SEWER 

PROPOSED 65mmØ FOUL RISING MAIN 

PROPOSED GULLY 

PROPOSED PUMP STATION 

PROPOSED FOUL INSPECTION CHAMBER 

PROPOSED 2 No. 125mmØ DUCTS
FOR POWER & VENTING 

PROPOSED PUMP CONTROLLER PANEL
WITH 100mmØ DUCT. 

**PLANNING DRAWING
NOT FOR CONSTRUCTION
ALL LEVELS GIVEN ARE
RELATIVE TO ORDNANCE DATUM
THIS DRAWING HAS BEEN ISSUED FOR INFORMATION
PURPOSES ONLY AND MUST NOT BE USED
FOR CONSTRUCTION UNDER ANY CIRCUMSTANCES**

1

1. For setting out refer to Architect's drawings.
2. This drawing to be read in conjunction with all other Architectural and Engineering drawings and all other relevant drawings and Specifications.
3. DO NOT SCALE THIS DRAWING. Use figured dimensions only.
4. No part of this document may be reproduced or transmitted in any form or stored in any retrieval system of any nature without the written permission as copyright holder except as agreed for use on the project for which the document was originally issued.
5. Ordnance Survey Ireland Licence Number EN 0074025.