KELLIHERS CONFIDENTIAL

SECTION 1 @ 1/250

SECTION 2 @ 1/250

GENERAL NOTES

1. ALL DIMENSIONS ARE GIVEN IN MILLIMETERS UNLESS OTHERWISE INDICATED.
2. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH THE SCOPE OF WORKS. ANY DISCREPANCIES ARE TO BE BROUGHT TO THE ATTENTION OF KELLIHERS FOR CLARIFICATION PRIOR TO ANY WORK COMMENCING.
3. CONTRACTOR TO FIELD VERIFY ALL DIMENSIONS, DISCREPANCIES ARE TO BE NOTIFIED TO THE CONTRACTOR AND DESIGN FOR RESOLUTION.
4. ALL WORKS TO COMPLY WITH PREVIOUSLY AGREED AND ISSUED SPECIFICATIONS

LEGEND

Grid 1
Results – Horizontal Illuminance (lux)
Eav= 8.14
Emin= 1.67
Emax= 15.30
Emin/Emax= 0.11
Emin/Eav= 0.21
Emax/Eav= 1.88

Grid 2
Results – Horizontal Illuminance (lux)
Eav= 7.83
Emin= 1.74
Emax= 14.85
Emin/Emax= 0.12
Emin/Eav= 0.22
Emax/Eav= 1.90

Luminaire Data
Luminaire A TRSA–02–150–4L40719W
Lamp 8Du4L19W4K MF 0.76

Luminaire B XSPME – B – Type 4ME – 21W 4K
Lamp 3MD–SA1400 M 21W 4K MF 0.76

Key
- Luminaire A Column
- Luminaire B Column
- Beam Aiming Target
- Photometric Centre

All Dimensions in metres

REV. NO.	REVISION DESCRIPTION	DRAWN	CHECKED	APPROVED	DATE
1	LAYOUT REVISED – REISSUED FOR COUNCIL APPROVAL	DMD	PS	PS	05JUL23
0	ISSUED FOR COUNCIL APPROVAL	DMD	PS	PS	13DEC21

THIS DRAWING CONTAINS INFORMATION WHICH IS THE PROPERTY OF KELLIHERS LTD. THIS DRAWING IS RECEIVED IN CONFIDENCE AND ITS CONTENTS MAY NOT BE DISCLOSED WITHOUT THE PRIOR WRITTEN CONSENT OF KELLIHERS LIMITED.

APPROVALS		DATE
DRAWN	DMD	13DEC21
DESIGNED	DMD	13DEC21
REVIEWED	PS	13DEC21
SAFETY	–	–
LAYOUT	DMD	13DEC21
ENGINEER	PS	13DEC21
APPROVED	PS	13DEC21
CUT CODE	CREE	

PROJECT: HEATHFIELD RESIDENTIAL

KELLIHERS ELECTRICAL LTD.
M50 BUSINESS PARK ,
BALLYMOUNT,
DUBLIN 12

HEATHFIELD RESIDENTIAL
CARRIGANARRA BALLINCOLLIG
LIGHTING LAYOUT - PHASE 3
CREE LED

FILE NO.	FILE NAME	DRAWING NO.	REV
–	KE/HCB/01	KE/HCB/05	1
SLD-DWG NO.	PLOT SCALE	DRAWING SCALE	SHEET
–	TO FIT	1/250@A0	1 – 2

A0

DO NOT SCALE. Use Printed Dimensions Only